## ETALIN HYDRO ELECTRIC POWER COMPANY LTD. (EHEPCL) PQ. No.: EHEPCL/PQ-001/2014/Package-4 Dated 18.07.2014

## Amendment No. PQ-001/PKG-4/01 Dated 19.09.2014

Sl. No.	PQ Criteria reference Clause	Amended/ to be read as
P-4-1	3.3.1.2. b. 2. U/G Desilting Basin (i):	3.3.1.2. b. 2. U/G Desilting Basin (i):
	Completion of an underground Desilting Basin of 15m width	"Completion of all civil works of atleast one underground de-silting basin".
P-4-2	3.3.1.3 Hydro-Mechanical Works b.Specific Expereince:	3.3.1.3 Hydro-Mechanical Works b.Specific Expereince:
	Successful completion of the following hydro-mechanical works in the preceding fifteen (15) years:	Successful completion of the following hydro-mechanical works in the preceding fifteen (15) years:
		Design, manufacture, supply, erection, testing and commissioning of Radial Gates operated by twin hydraulic cylinders for spillways under submerged condition, and having A x H $\geq$ 2300 and H $\geq$ 26m. OR
	Design, manufacture, supply, erection, testing and commissioning of Radial Gate operated by twin hydraulic cylinders and having A $\times$ H $\geq$ 2700 and H $\geq$ 16m, and Association with a design firm/company which has successfully completed basic and detailed design of submerged type spillway radial gates of minimum design head of 26m.	Design, manufacture, supply, erection, testing and commissioning of Radial Gate operated by twin hydraulic cylinders and having $A \times H \ge 2300$ and $H \ge 16m$ , and Association with a design firm/company which has successfully completed basic and detailed design of submerged type spillway radial gates of minimum design head of 26m.