

ETALIN HYDRO ELECTRIC POWER COMPANY LTD. (EHEPCL)
PQ. No.: EHEPCL/PQ-001/2014/Package-EM1 & EM2 Dated 18.07.2014

Clarification No. PQ-001/PKG-EM1 & EM2/01 Dated 29.09.2014

Sr No	PQ Criteria	Clarification Sought	Clarified as
P-EM1 & EM2- (1)	3.3.1 (b) (vii) Generator Step up (GSU) Transformers <u>Pakage-EM1</u> & <u>Pakage-EM2</u>	We understand following: 1) A total of 4 nos. of three phase GSU transformers having minimum rating of 300 MVA and voltage level of minimum 400 kV can be taken from two projects. 2) For the purpose of transformers, project shall also include the transformers supplied to sub-station. Kindly confirm our understanding.	1) Minimum numbers of requisite three phase GSU transformers in each Package can be from two operational projects. 2) Transformers supplied to Hydro, Thermal, Gas, Nuclear plants and Sub-Stations shall be considered.
P-EM1 & EM2- (2)	3.3.1 (b) (v) Gas Insulated Switchgear (GIS) <u>Pakage-EM1</u> & <u>Pakage-EM2</u>	We understand that 10 nos. and 6 nos. bays in respective EM Package are cumulative in nature and could be taken from more than one projects.	It can be taken from more than one project.
P-EM1 & EM2- (3)	Appendix-B : Prequalification Forms	Request to please provide the Editable copy of Various Forms and Letter covered under Appendix-B : Prequalification Forms (Letter of Application and Form-1 to Form-11) for both packages as this will help us in preparing the PQ bid.	Not Agreed.